

Rainbow Filters Pty. Ltd.

Unit 1, 383 Dorset Road,
Bayswater Vic 3153, Australia

TEL: 1300 365 659

FAX: 1300 365 243

www.rainbowfilters.com.au



TEST CERTIFICATE

EN1822-1:2009 STANDARD METHOD AIRFLOW -VS- INITIAL RESISTANCE AND INITIAL DEHS REMOVAL EFFICIENCY

1. Description

Product Name:	HEPA Minipleat Filter Efficiency:H14						
Product Size(mm):	315	X	215	X	50	Air Flow Rated 100% (CFM):	151
Product Size(inch):	12.40	X	8.46	X	1.97	(CMM):	4.2733

2. Efficiency Test Conditions

Test Aerosol:	DEHS @ 0.3 Micron
Scan Test:	MCHE 01
Scan Velocity(M/Sec):	1.2±0.05

3. Test Result

Serial No.	Structure	Leakage Scan	Capacity (CFM)	Average Efficiency (%)	Initial Pressure Drop (Pa)	Customer	Notes
20220606038003	✓	✓	151	99.992	233		

4. Other Notes

--

We hereby certify that the above product complies with the terms of the order. In addition, we certify that the filter has passed the required control tests and we guarantee the minimum efficiency under properly operation.

Date: 2022/6/20